



UROX.S24127 Smoke-automatic Fire Detectors

[Page Bottom](#)

Smoke-automatic Fire Detectors

[See General Information for Smoke-automatic Fire Detectors](#)

CONTEXT PLUS LTD

175 MAULDETH RD
MANCHESTER, ENGLAND M14 6SG UNITED KINGDOM

S24127

| Detector | | | Compatibility | Velocity Range (fpm) | | |
|--------------------------|-------|-------------|---------------|----------------------|--------------|-----|
| | Model | Application | | Type | Restrictions | Min |
| 55000-226 IMC | OAP | I | D2 | 0 | 300 | |
| 55000-326 IMC (a) | OAP | P | D2 | 0 | 300 | |
| 58000-550IMC | OAP | I | D2 | 0 | 300 | |
| 58000-650IMC | OAP | P | D2 | 0 | 300 | |
| 58000-750IMC | OAP | P(IHD) | D2 | 0 | 300 | |

| Base Model | Related Detector | Control Unit Compatibility Restrictions |
|----------------------|--|---|
| 45681-200 IMC | 55000-326 IMC, 55000-226 IMC | B2 |
| 45681-210IMU | 58000-450IMC, 58000-550IMC, 58000-650IMC, 58000-750IMC | B2 |

B2 - For connection to Listed control units with which compatibility was determined by test or a review of circuit parameters. Interconnection and compatible models indicated on installation wiring diagram for detector (base) and/or control unit.

D2 - For connection to Listed control units with which compatibility was determined by test or a review of circuit parameters. Interconnection and compatible models indicated on installation wiring diagram for detector (base) and/or control unit.

OAP - Open Area Protection

I - Ionization

P - Photoelectric

IHD - Includes Integral Heat Detector

(a) - Suitable for use in ambient temperatures of 0-60 C (32-140 F).

[Last Updated](#) on 2013-06-10

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2013 UL LLC

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2013 UL LLC".