



## UQGS.S24128 Heat-automatic Fire Detectors

[Page Bottom](#)

### Heat-automatic Fire Detectors

[See General Information for Heat-automatic Fire Detectors](#)

#### CONTEXT PLUS LTD

S24128

175 MAULDETH RD  
MANCHESTER, ENGLAND M14 6SG UNITED KINGDOM

Model No.	Type	Compatibility Restrictions	Contact Arrangement	Temp Range (°F)	Spacing (Ft)	
					Smooth Ceiling	to Wall or Partition
55000-139 IMC	FT/ROR	D2	-	135	50	25
55000-145 IMC	FT/ROR	D2	-	200	50	25
58000-450IMC	FT/ROR	*1	-	135 (m1)	70	35
				150 (m2 / m3)	70	35
				200 (m4 / m5)	70	35

Base Model	Related Detector	Control Unit Compatibility Restrictions
45681-200 IMC	55000-139 IMC, 55000-145-IMC	#1
45681-210IMU	58000-450IMC	#1

D2 - For connection to Listed control units with which compatibility was determined by test or a review of circuit parameters. Interconnection and compatible models indicated on installation wiring diagram for detector (base) and/or control unit.

#1 - For connection to Listed Control units Models ZXa and ZXe, manufactured by Morley IAS, employing software revision greater than 684aU0.

\*1 - For connection to Listed Control units Models ZXa and ZXe, manufactured by Morley IAS, employing software revision greater than 684aU0.

FT/ROR - Fixed temperature/rate of rise combination

[Last Updated](#) on 2013-11-19

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2013 UL LLC

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2013 UL LLC".