



The mentioned product
complies with the mentioned
test requirement

Intertek LSS Scheme Tick Mark Certificate

15LHK0955-01

In accordance with the Tick Mark Rules and Certification System 5,
as defined in ISO / IEC Guide 67, we certify that the product

ZFP range of Addressable Fire Alarm panels, XP95 / Discovery Protocol
is in conformity with the following standard(s)

EN54-2:1997+A1:2006, EN54-4:1997+A1:2002+A2:2006

Report Number(s): 101237162

Context Plus Limited

Export House, 175 Mauldeth Road, Fallowfield, Manchester, M14 6SG, United Kingdom
is authorised to use the Intertek Tick Mark for the LSS Scheme on the above mentioned
product

This certificate is valid until:

27 July 2019

This Certificate is issued in accordance with the Certification Regulations governing its use and in reliance on the undertaking given by the Licensee and only extends to the use in respect of the goods produced to an acceptable degree of compliance with the Approval Standard. This Certificate is not transferable and remains the property of Intertek Testing and Certification Ltd.

Limitations:	Certification body: ITCL
	LSS Ref: LSS 0497
	Issued Date: 20 August 2015

Signed on behalf of Intertek, located at Leatherhead, United Kingdom



010

Oliver Richardson
Operations Manager



Page 1 (see model details on page 2)



The mentioned product
complies with the mentioned
test requirement

Intertek LSS Scheme Tick Mark Certificate

15LHK0955-01

The tested product fulfills the criteria based on the Intertek Tick Mark Specification according to the guideline and is therefore awarded the Intertek Tick Mark. The Intertek Tick Mark may be used by the applicant in connection with sales and marketing in order to demonstrate and verify the performance of the tested product.

ANNEX No 1

The optional features of the specifications that are included in the product and test report:

- 7.8 Output to fire alarm devices
- 7.11 Delays to outputs
- 7.12 Dependencies on more than one alarm signal
- 7.13 Alarm counter
- 8.3 Fault signals from points
- 9.5 Disabling of addressable points
- 10 Test Condition

Brand and Type/Model	Description	Factory Code
Z013040NS/X/CON	1 Loop fire alarm control panel	CTECUK.01
Z023040NS/X/CON	2 Loop fire alarm control panel	CTECUK.01
Z043040NS/X/CON	4 Loop fire alarm control panel	CTECUK.01



The mentioned product complies with the mentioned test requirement

Intertek LSS Scheme Tick Mark Certificate

15LHK0955-01

The tested product fulfills the criteria based on the Intertek Tick Mark Specification according to the guideline and is therefore awarded the Intertek Tick Mark. The Intertek Tick Mark may be used by the applicant in connection with sales and marketing in order to demonstrate and verify the performance of the tested product.

ANNEX No 2

Products compliant with EN54-2:1997+A1:2006

Variant	Description
Z013040NS/X/CON	Loop fire alarm control panel
Z023040NS/X/CON	Loop fire alarm control panel
Z043040NS/X/CON	Loop fire alarm control panel

Product variants:

Variant	Description
Z013040NS/X/CON	1 Loop fire alarm control panel

Comprising of:

Z41	Control module, c/w touchscreen, access key switch and 16 LEDs (5 key switches)
Z48	40-zone indicator module
BF362-5	Power supply (fitted within CIE enclosure)

Optional:

Z11	4 Relay PCB
Z12	8 Relay PCB
Z13	8 I/O PCB
Z14	16 I/O PCB



The mentioned product complies with the mentioned test requirement

Intertek LSS Scheme Tick Mark Certificate

15LHK0955-01

The tested product fulfills the criteria based on the Intertek Tick Mark Specification according to the guideline and is therefore awarded the Intertek Tick Mark. The Intertek Tick Mark may be used by the applicant in connection with sales and marketing in order to demonstrate and verify the performance of the tested product.

Variant	Description
Z023040NS/X/CON	2 loop fire alarm control panel
Comprising of:	
Z41	Control module, c/w touchscreen, access key switch and 16 LEDs (5 key switches)
Z48	40-zone indicator module
BF362-5	Power supply (fitted within the CIE enclosure)
Optional:	
Z11	4 Relay PCB
Z12	8 Relay PCB
Z13	8 I/O PCB
Z14	16 I/O PCB

Variant	Description
Z043040NS/X/CON	2 loop fire alarm control panel
Comprising of:	
Z41	Control module, c/w touchscreen, access key switch and 16 LEDs (5 key switches)
Z48	40-zone indicator module
Z02/LOOPX	Loop expansion board (1-off)
BF362-5	Power supply (fitted within the CIE enclosure)
Optional:	
Z11	4 Relay PCB
Z12	8 Relay PCB
Z13	8 I/O PCB
Z14	16 I/O PCB



The mentioned product
complies with the mentioned
test requirement

Intertek LSS Scheme Tick Mark Certificate

15LHK0955-01

The tested product fulfills the criteria based on the Intertek Tick Mark Specification according to the guideline and is therefore awarded the Intertek Tick Mark. The Intertek Tick Mark may be used by the applicant in connection with sales and marketing in order to demonstrate and verify the performance of the tested product.

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

